



GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE EXTRA ASSISTANT COMMISSIONER
WEST KAMENG DISTRICT:: BHALUKPONG

EAC

No. BPP/3/Fire Service-01/2015

Dated Bhalukpong, the 20th June' 2023.

NO OBJECTION CERTIFICATE


This is to certify that the Govt. Secondary School, Bhalukpong having 10 class room building located at Bhalukpong, West Kameng District, Arunachal Pradesh is equipped with the required fire protection in School buildings and was inspected today on 20/06/2023 and fire risk observed were of low category and evacuation in case of emergency cannot be a problem.

The General Administration has No Objection to the above school as it is well protected by fire appliances.

4.5 kg capacity Co2 type fire Extinguishers = 4 Nos.

All fire equipments installed shall be maintained in working order throughout the validity period of the certificate.

This Certificate is valid for six months.


(Sumita Jongkey) CO,
For Extra Assistant Commissioner,
Bhalukpong,
Per Extra Assistant Commissioner
Bhalukpong, West Kameng Dist. (A.P.)